



SQ1 - NON-CONDENSABLE GAS TEST



Name Techno Air Gate (TAG)
Address 2311 Abdulsalam Amin St., 2nd District, 6th October, Giza, Egypt.
Email/Tel info@technoairgate.com

Site

JAMJOOM PHARMA

Date

Sunday, May 25, 2025

Location / Sterilizer

Water station WFI Tank

Code

--

TEST

Cycle No

1

2

3

Average

Volume of gas at start of test (ml)

0.0

0.0

0.0

Volume of gas at end of test (ml)

1.7

1.3

1.4

Volume of condensate at start of test (ml)

0.0

0.0

0.0

Volume of condensate at end of test (ml)

100.0

100.0

100.0

Non-condensable gas level (%)

1.7%

1.3%

1.4%

1.5%

Requirements of EN 285

NMT 3.5%